

COMPANY REG NO 2172813

AutoMeg Test Report - All readings shown

Part Number C19-04WC16 5M 16A DIGIAM
Description 4WAY C19 5M 16A DIGIAMM
Issue (ref)
Job No Name 98446 AA
Job No Name 98446 AA
Number 001

HV1 Test

Current (mA)	1000	AC/DC	DC
Clamp (V)	30.0	Voltage (V)	200
Nominal (ohm)	0.100	Ramp (s)	0.5

Threshold (%) 25 Pre-dwell (s) 0.0
Dwell (s) 0.0 Measure (s) 0.5
Offset (ohm) 0.000 Ins (Mohm) 50.0

Continuity Test (Connections and shorts) 1 of 1(Default description (ST 1)) Continuously

Nominal-ohms	Minimumohms-	Maximum-ohms	Actual-ohms	Status	
1 5	0.094	0.070	0.117	0.092	PASS
1 8	0.187	0.070	0.233	0.115	PASS

1	11	0.105	0.078	0.131	0.107	PASS
---	----	-------	-------	-------	-------	------

1	14	0.106	0.079	0.132	0.105	PASS
---	----	-------	-------	-------	-------	------

2	6	0.114	0.085	0.142	0.105	PASS
---	---	-------	-------	-------	-------	------

2	9	0.099	0.074	0.123	0.097	PASS
---	---	-------	-------	-------	-------	------

2	12	0.106	0.079	0.132	0.111	PASS
---	----	-------	-------	-------	-------	------

2	15					
---	----	--	--	--	--	--

		0.091	0.068	0.113	0.080	PASS
3	4					
		0.104	0.078	0.130	0.106	PASS
3	7					
		0.095	0.071	0.118	0.095	PASS
3	10					
		0.085	0.063	0.106	0.084	PASS
3	13					
		0.087	0.065	0.108	0.086	PASS
3	16					
		0.145	0.068	0.181	0.104	PASS

SHORTS TEST PASS

CONTINUITY TEST PASS

TEST PASS

Operator	JO	
Date	20-Apr-2007	-----
Start Time	15:38:20	TESTED
Duration	15:38:22	
Duration	00:00:02	-----

MK Test Systems Ltd Orchard Court Nr Taunton Somerset. England Phone : +44(0)1823 661100 Fax : +44(0)1823 661160 EMail : sales@mktest.com Web site : www.mktest.com Calibrated : 02/02/2007 Control software version : 2.146